



Notice Inviting Tender (NIT) for Structural Repairs, Waterproofing & laying of tremix for Exit Ramp in NABARD Head Office, Mumbai –400 051

Corrigendum

Ref. NIT No. NB/ DPSP/ HO/ Ramp Repair/2571/ 2023-24 dated 12.03.2024

The Notice Inviting Tender had been published on NABARD Website and CPPP on 12th March, 2024. Accordingly, pre-bid meeting was conducted on 19th March, 2024. Representatives of the prospective bidders attended the pre-bid meeting. The queries raised by the bidders and clarification there against given by NABARD during the meeting are given below:

S.No	Query Raised by the bidders	Clarification Issued by NABARD
1	What will be the working hours allowed to execute the works?	The grouting and concreting works will only be allowed during day time in the presence of NABARD officials. For activities like dismantling of existing flooring, erection of scaffolding, etc. may be carried out upto extended hours with prior permission from Bank.
2	Whether the entire area where works are to be carried out as per the scope of works will be handed over during commencement of work?	As the works are related to repair of exit ramp and related structural elements, the same will be handed over entirely to the bidder for execution of work.

राष्ट्रीय कृषि और ग्रामीण विकास बैंक

National Bank for Agriculture and Rural Development

परिसर, सुरक्षा एवं अधिप्राप्ति विभाग

प्लॉट क्र सी-24, 'जी' ब्लॉक, बान्द्रा-कुर्ला कॉम्प्लेक्स, बान्द्रा (पूर्व), मुंबई - 400 051. टेली: +91 22 2653 0035 • फ़ैक्स: +91 22 2653 0060 • ई मेल: dpsp@nabard.org

Department of Premises, Security & Procurement (DPSP)

Plot No. C-24, 'G' Block, Bandra-Kurla Complex, Bandra (E), Mumbai - 400 051 • Tel.: +91 22 2653 0035 • E-mail: dpsp@nabard.org

गाँव बढ़े >> तो देश बढ़े

www.nabard.org

Taking Rural India >> Forward



3	Does the quantity of the concrete grouting (S.No. 5) in BoQ (Price Bid) also include the quantity of the cement used for grout?	As per the item description of the BoQ, the quantity is the quantity of grout as a whole consumed against the item i.e., cement and polymer.
4	Whether necessary support arrangements like props are to be provided beneath the slab of ramp and structural elements for support while undertaking structural repair works?	Yes. The bidder is responsible for providing necessary support arrangements to the structural elements while carrying out the repair/ concrete works and bidders have to consider the expense towards these arrangements while quoting their rates for the work.

II. This corrigendum will form part of the NIT.

III. All other terms & conditions as per original NIT remain unchanged.

(A K Pittan)

Deputy General Manager

DPSP, NABARD Head Office

Mumbai – 400 051

Date : 21.03.2024